



LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.
Sede Primaria: I-59100 PRATO - Via della Quercia, 11
Telefono +39 0574.575.320 - Telefax +39 0574.575.323
Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48
e-mail: lapi@laboratoriolapi.it
web site: www.laboratoriolapi.it

Reg. 305/2011
Notified Body N°0987

CLASSIFICATION ASSESSMENT ACL/128/18/CPR/50575

When applicable the following document has been issued in compliance with the Regulation UE 305/2011 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products, it has been stated that the construction product :

REACTION TO FIRE CLASSIFICATION REPORTS N°. 128.ODC0075/18

CLASSIFICATION EFFECTED BY
LAPI S.p.A. Construction Product Regulation 305/2011/EU Notified Body 0987

CLASSIFICATION ON BEHALF OF
HANGZHOU XINGFA TECHNOLOGY CO LTD
82 Tianzhu Street, Linan Industrial Zone, Hangzhou, Zhejiang, CHINA, 311305

MATERIAL CLASSIFIED

COAXIAL CABLE

Cable tested

Re. Lab. no.	Denomination
128/18	COAXIAL CABLE RG6 (Nominal diameter: 6.6~7.2 mm)



DESCRIPTION OF THE MATERIALS

Cables with LSZH sheath

TEST METHODS

CEI EN 60332-1-2:2006/A1:2016 + CEI EN 60332-1-1:2006/A1:2016, EN 60332-1-2:2004/A11:2016 + EN 60332-1-1:2004/A1:2015;
CEI EN 50267-2-3:1999 + CEI EN 50267-1:1999, EN 50267-2-3:1998 + EN 50267-1:1998; EN 50399:2016-09

PRODUCT STANDARD

EN 50575 : 2014 + A1 : 2016 (AVCP system 3)

CLASSIFICATION STANDARD

EN 13501-6:2018

Fire classification of construction products and building elements -
Part 6: Classification using data from reaction to fire on electrical cables

CLASSIFICATION

C_{ca}-s1,d0,a1

The above reported classification is valid only for the cables reported in the table above.

The Laboratory has not been involved in any sampling activity. As the cables has obtained this classification, it is valid for all lower classes.
This document is issued within the AVCP 3 system for EN 50575 for classes not higher than Dca, this one included. This document, issued on 20/04/2023 is the renewal of the former one issued on 26/02/2018

Prato, 20/04/2023

Valid until: 19/04/2028

The Certification Manager

Dr. David Borsini

The Director of the Laboratory

Dr. Luca Ermini



Questo documento deve essere letto congiuntamente ai Rapporti di Prova, per la descrizione del prodotto e per ogni altra notizia di dettaglio. Questo documento non costituisce approvazione di tipo né certificazione di prodotto né tantomeno dichiarazione di conformità, che spetta esclusivamente al Produttore / Sponsor.

This document has to be read in conjunction with the Test Reports, for the description of the product and for every other detail. This document does not represent type approval or certification of the product neither declaration of compliance, that is exclusively under the responsibility of the Manufacturer or Sponsor.

Il presente Rapporto di Prova non può essere riprodotto in forma parziale senza l'autorizzazione scritta di questo Laboratorio